



When to Call Your HERS Rater

For the project's specific HERS requirements, refer to the "HERS feature Summary", located on the CF1R, typically Page 3.

Project Phase	HERS Inspection to be Verified at Installation	Task to Verify	Req'd? Y/N	Task Complete (HERS Rater Initials)	Date Verified
Kick Off Meeting with Trades & Builder	Review all HERS measures selected for the project with the HERS Rater	Failure to do so may result in added cost and schedule delays			
Foundation	Quality Insulation Installation	<ul style="list-style-type: none"> Perimeter/Under slab Insulation Raised Floor 			
Framing	Quality Insulation Installation	<ul style="list-style-type: none"> Exterior Corners Tubs, Fireplaces, Stairs 			
Insulation	Quality Insulation Installation	<ul style="list-style-type: none"> R-value specified Air sealing, incl. electrical penetrations Fan penetrations 			
	Reduced Building Air Leakage	<ul style="list-style-type: none"> Blower door test 			
Plumbing	Pipe insulation credit	<ul style="list-style-type: none"> R-Value 			
	Recirculation System	<ul style="list-style-type: none"> Demand Control Type Location of sensors/control 			
HVAC	IAQ Fan (Exhaust/Balanced/Supply)	<ul style="list-style-type: none"> CFM matches CF1R Type matches CF1R 			
	Kitchen Hood	<ul style="list-style-type: none"> CFM & HVI Certified 			
	Visual Inspection of HVAC System in Conditioned Space	<ul style="list-style-type: none"> Location of Unit Location of Ducts & R-Value Efficiencies 			
	Variable Capacity Heat Pump (VCHP)	<ul style="list-style-type: none"> Refer to HERS Feature Summary, items showing (SC3.X) 			
	Duct Leakage Testing	<ul style="list-style-type: none"> Sealed boots Meets the leakage requirement Efficiencies of Equipment 			
	Low Leakage Air Handler	<ul style="list-style-type: none"> Unit Specification confirmed <5% credit taken confirmed 			

Questions? Call an Energy Code Coach at **(805) 781-1201**